



TYPICAL
OPEN LOOP
INSTALLATION
WELL TO WELL

- DO NOT BLOCK FILTER ACCESS WITH PLUMBING
- DO NOT PUNCTURE AIR COIL WITH SCREWS WHEN DUCTING
- UNITS EQUIPED WITH AUX HEAT REQUIRE 2 INDIVIDUAL HIGH VOLTAGE CIRCUITS
- AIR HAMMER ON LEAVING SIDE CRITICAL
- LARGER DIAMETER PIPE SIZING ON RETURN CAN ELIMINATE WATER NOISES