

NOTES:

- 1) SEE UNIT NAME PLATE FOR ELECTRICAL RATING
- 2) ALL FIELD WIRING MUST BE IN ACCORDANCE WITH N.E.C.-N.F.P.A. #70.
- 3) ALL 208/230 VOLT BLOWER MOTORS EXCEPT HE031 AND HE041, 460 AND 575 VOLT BLOWER MOTORS ARE SINGLE SPEED



FHP
 ENERGY MISER
 ENVIRONMENT
 SYSTEMS
 FHP MANUFACTURING
 & Harrow company


SCALE NONE	DRAWING # WD-122	DRAWN BY K.M.N.
DATE 2-5-92		REVISION 4-8-92

WIRING DIAGRAM
 THREE PHASE - ALL VOLTAGES
 HE031-062 & SE053-063
 MODEL HEAT PUMPS

VOLTAGE DESIGNATOR	LINE VOLTAGE THREE PHASE/60 Hz
- 3	208/230
- 4	460
- 5	575

POWER SUPPLY L1, L2, L3 (USE COPPER CONDUCTORS ONLY)

LINE VOLTAGE 
 LOW VOLTAGE 



UNIT TERMINALS
 D — (D)
 Y — (Y)
 R — (R)
 G — (G)

STANDARD T-STAT CONNECTIONS