

NOTES:

- 1) SEE UNIT NAME PLATE FOR ELECTRICAL RATING.
- 2) ALL FIELD WIRING MUST BE IN ACCORDANCE WITH N.E.C.-N.F.P.A. #70.
- 3) ALL 208/230 VOLT BLOWER MOTORS EXCEPT HE031 AND HE041, 460 AND 575 VOLT BLOWER MOTORS ARE SINGLE SPEED



ENERGY MISER
ENVIRONMENT
SYSTEMS
FHP MANUFACTURING
a Harrow company

SCALE NONE	DRAWING # WD-126	DRAWN BY K.M.N.
DATE 2-5-92		REVISION 4-8-92

WIRING DIAGRAM
THREE PHASE - ALL VOLTAGES
LT040-070 & SL055-065
MODEL HEAT PUMPS

VOLTAGE DESIGNATOR	LINE VOLTAGE THREE PHASE/60 Hz
- 3	208/230
- 4	460
- 5	575

POWER SUPPLY L1, L2, L3 (USE COPPER CONDUCTORS ONLY)

LINE VOLTAGE
LOW VOLTAGE

LINE VOLTAGE
(BY OTHERS)

